



October 29, 2020

Thomson Lake Regional Park
Box 520
LAFLECHE, SK S0H 2K0

Dear Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory – Thomson Lake Regional Park

The Water Security Agency (WSA) is issuing a "**Precautionary Drinking Water Advisory**" to the users of the **Thomson Lake Regional Park** water system due a depressurization to facilitate a water line repair.

Although there has been no indication of problems associated with bacteria or protozoa in the water, the potential for contamination exists at this time. Therefore, WSA is issuing a "**Precautionary Drinking Water Advisory**" (PDWA) for the users of the Thomson Lake Regional Park's potable water system.

This ADVISORY is in effect **immediately on Thursday October 29, 2020** for the users in Thomson Lake Regional Park and will be in effect until bacteriological water quality results are acceptable. Therefore, I ask that the administration notify all users of the drinking water distribution system that they boil the water used for drinking purposes for at least one minute prior to use. Bottled water can be a safe alternative.

This "**Precautionary Drinking Water Advisory**" shall remain in effect until the water is bacteriologically free and safe for consumption. Should you have any questions or concerns, please contact Lauren Daly at (306) 630-7485.

Sincerely,

A handwritten signature in blue ink that reads "Lauren Daly".

Lauren Daly, B.Sc. Hons
Environmental Project Officer
Water Security Agency

Precautionary Drinking Water Advisory

Sampling Procedure

Once the system is pressurized and flushed according to applicable standards and the minimum free chlorine residuals are being met in the distribution system, the following sampling is required:

1. Take 3 bacti samples from different locations in the distribution system, on the first day.
Be sure to check "Other" on the sample submission forms.
2. Take 3 bacti samples from different locations in the distribution system on the second day. **Be sure to check "Other" on the sample submission forms.**

Sampling should be conducted early in the week to ensure timely delivery of samples to the lab. Samples must be processed within 48 hours of collection.